

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
S 60102563

Blatt *Page*
0001

Ihr Zeichen *Client Reference* Unser Zeichen *Our Reference* Längstens gültig bis *Latest expiration date*
S 60102563 0001-- 28221642 004 16.10.2019 (day/mo/yr)

Genehmigungsinhaber *License Holder*
DALAP GmbH
Töpfergasse 72
09526 Olbernhau
Germany

Fertigungsstätte *Manufacturing Plant*
0001--28221642 001

Prüfzeichen *Test Mark*



www.tuv.com
ID 1000000000

Gepprüft nach *Tested acc. to*

EN 60335-1:2012+A11
EN 60335-2-80:2003+A1+A2
EN 62233:2008
ZEK 01.4-08/11.11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Ventilator Fans

Bezeichnung /Type designation:	Bemessungsaufnahme /Rated power input:	
AP 100 x ;	21W / 33W	10
AP PROFI 100 ;	23W / 25W	
AP 125 x ;	23W / 37W	1
AP 125 STARK ; AP 125 STARK T ;	28W / 54W	
AP PROFI 125 ;	25W / 30W	
AP 150 x ; AP 160 x ;	30W / 60W	2
AP PROFI 150 ; AP PROFI 160 ;	42W / 50W	
AP 200 x ; AP PROFI 200 ;	76W / 108W	1
AP 250 x ; AP PROFI 250 ;	125W / 177W	1
AP 315 x ; AP PROFI 315 ;	230W / 320W	1

Trade Mark: dalap
Bemessungsspannung/Rated voltage: 220-240V~, 50Hz
Schutzart/Degree of protection: IPX4
Schutzklasse/Protection class: II
Wo/where x = blank; Z; T; (Function)

16

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Produkt und Fertigungsstätte erfüllen § 20 und § 21 des
Produktsicherheitsgesetzes.
*This certificate is based on our Testing and Certification Regulation.
Product and production fulfill par § 20 and § 21 of the
Product Safety Law.*

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



G. Bakos

Ausstellungsdatum *Date of Issue* : 23.06.2015 (day/mo/yr)

CERTIFICATE of Conformity



Certificate No.: MK 69249979 0001

Test Report No.: 28221642 004

Certificate Holder: DALAP GmbH
Töpfergasse 72
09526 Olbernhau
Germany

Manufacturer: ---

Product: Fans

Identification: Type designation: Dalap AP z xxx u yyyy

Trade Mark: Dalap
Rated Voltage: 220-240V; 50Hz
Degree of protection: IPX4
Protection class: II
Tamb: 1-40°C

See detailed information in Annex.

Tested according to: EN 60335-2-80:2003+A1+A2
EN 62233:2008
EN 60335-1:2012+A11

This certificate refers to the above mentioned product. This is to certify that the test sample is in conformity with the requirements stated above. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Date of Issue:

Budapest, 2015.06.18



TÜV Rheinland InterCert Kft. – Product Certification Body — H-1132 Budapest, Váci út 48/A-B — www.tuv.hu
IT_07-D-Pe_4_0

Identical fan type Dalap AP series	Rated Input (W)
AP 100	21/33
AP 100 Z	
AP 100 T	
AP 125	23/37
AP 125 Z	
AP 125 T	
AP 125 STARK	28/54
AP 125 STARK T	
AP 150	30/60
AP 150 Z	
AP 150 T	
AP 160	
AP 160 Z	
AP 160 T	76/108
AP 200	
AP 200 Z	
AP 200 T	125/177
AP 250	
AP 250 Z	
AP 250 T	230/320
AP 315	
AP 315 Z	
AP 315 T	23/25
AP PROFI 100	
AP PROFI 125	
AP PROFI 150	
AP PROFI 160	
AP PROFI 200	
AP PROFI 250	
AP PROFI 315	

The meaning of characters:

Dalap: trade mark

AP: design

z: it can be blank or PROFI, that means plastic airflow deflector provided xxx: diameter of the duct [mm]. It can be: 100,125,150,160,200,250,315

u: it can be or blank or Stark that means increased capacity

yyyy: It can be blank or

Z: timer

T: with electronic "temperature" module and temperature sensor

Date of issue:

Budapest, 2015.06.18.

